Baseline Evaluation of XAFS Bending Magnet Beamlines

Experiments performed under "*standard optimized operating conditions*," as recorded.

Steve Heald

Matt Newville Mali Balasubramanian

Julie Cross

- Rhodium coated harmonic rejection mirror, angle varies. See notes for specific test.
- The SRS-570 current amplifier gain settings are recorded in the data file headers.
- A 10% DC offset on the SRS-570 was automatically corrected by the data acquisition software.
- \circ The monochromator was detuned by 10% on the preslit detector.
- Feedback stabilization was not used, although it is available.
- The beam was unfocused, although vertical focusing is possible with the 20-BM HR Mirror.
- \circ Dry N₂ flowing in IO[15 cm] and IT[30 cm] ionization chambers.
- Chambers operating at 600 VDC, except where noted.
- o 7 GeV electron synchrotron operating in top-up mode, 100 mA (nominal).
- IO entrance slits 1.1 mm vertical x 10 mm horizontal.

N.B. Sector 21 is under construction, so this is probably a worst-case-scenario for noise (audible noise-ugh!!).

5/2/06

ENERGY CALIBRATION: Experiment log

XANES scans of metal foil reference standards collected over a large energy range without recalibrating the monochromator.

- Metal foils from EXAFS Company (Joe Wong). Set provided by M. Newville.
- For the low energy range (V, Cr, Cu and Zn), harmonic rejection mirror set to 5 mrad.
- Cutoff ca. 13,400 eV.
- All XANES collected at 0.2 sec/point, unless otherwise noted.

file name	foil	edge energy		step size
		nominal†	measured‡	
cufoil.0001	Cu	8980.48(2)	8980.1	0.4 eV
znfoil.0001	Zn	9660.76(3)	9660.8	0.4
crfoil.0001	Cr	5989.02(4)	5988.91	0.3
vfoil.0001	V	5463.76(5)	5464.04	0.3

Changed beamline settings to work at the high energy range. Changeover took about 1/2 hour, not including detector gas equilibration time.

- For the high energy range (Mo, Ag), harmonic rejection mirror set to 2.3 mrad.
- Cutoff ca. 29,130 eV.
- \circ IO entrance slits reduced to 0.8 vertical x 10 mm horizontal.
- Switch to Ar in IO[15 cm] and IT[30 cm] at 600 VDC for Mo and Ag XANES.
- Detector gases allowed to equilibrate while we all go for lunch, coffee, etc. around 12:45.

file name	foil	edge energy		step size
		nominal†	measured‡	
mofoil.0001	Мо	20,000.36(2)	20,001.9	0.8 eV
agfoil.0001	Ag	25,515.6(3)	noisy, split peak	0.8 eV

We see a double peak in the 1st derivative of agfoil.0001, and assume it is noise.

• Increase counting time to 0.5 sec/point.

file name	foil	edge energy		step size
		nominal†	measured‡	
agfoil.0002	Ag	same	25,521§	0.8 eV

⁺Rev. Sci. Instrum., **67** (1996) 686.

[‡]Using first peak in first derivative of XANES scan taken at the beamline with LabView DAC.

§May need to apply a smoothing algorithm to the Ag XANES to get a decent derivative.

ENERGY CALIBRATION: V K data (Athena screen shots)



ENERGY CALIBRATION: Cr K data







3

ENERGY CALIBRATION: Zn K data



ENERGY CALIBRATION: Mo K data









ENERGY CALIBRATION: Results

file name	foil	edge energy		
		nominal†	measured‡	difference
vfoil.0001	V	5463.76(5)	5463.82	0.06
crfoil.0001	Cr	5989.02(4)	5989.49	0.47
cufoil.0001	Cu	8980.48(2)	8980.21	-0.21
znfoil.0001	Zn	9660.76(3)	9662.02	1.26
mofoil.0001§	Mo	20,000.36(2)	20002.05	1.69
agfoil.0002§	Ag	25,515.6(3)	25526.35	0.75

⁺Rev. Sci. Instrum., **67** (1996) 686.

tUsing first peak in first derivative of XANES scan, after application of Athena smoothing algorithm, with the exception of the Mo XANES, which was processed using a spline smoothing algorithm.

§High energy edges measured with Ar in IO and IT; detectors gases equilibrated ca. 1 hour, over lunch break.



20 BM Monochromator Calibration

Tabulated Absorption Edge (eV)

ENERGY RESOLUTION: Experiment log

Measure the full width at half maximum of the V_2O_5 pre-edge feature.

• The sample is powder-on-tape prepared by Matt Newville.

- Harmonic Rejection Mirror set to 6 mRad.
- cutoff of ca. 11,179 eV.

○ Scan details: pre-edge -100 to -20 eV, Post-edge 30 eV to 8k (240 eV) for accurate normalization.

filename	slit size		FWHM of feature	step size
	V	Н		
V2O5.0002	1.1 mm	6 mm		0.2 eV
V205.0003	600 µm	6 mm	1.865 +/- 0.018 eV	0.2 eV



HARMONIC CONTENT: Experiment log

Scan the energy around 6.66 keV through a Mo foil to look for emergent Mo XANES from the third harmonic.

- \circ Nominal edge position for Mo is 20,000 eV. Run a XANES scan with EO = 6,6667.
- Harmonic rejection mirror set to 8.5 mRad.
- nominal cutoff ca. 7880 eV.
- \circ Limiting factor in HR cutoff is tilting the BM table. N_2 in both chambers.
- \circ IO is 15 cm, IT is 30 cm gas ionization at 600 VDC.
- \circ 25 μ m thick Mo foil from the PNC set of foil standards.

filename	IT	IO	v/f counts	sec/pt
moharmonic.0001	20 pA/v	10 nA/V		0.2
moharmonic.0002	same	same	100 (basically noise)	1.0
monochromator fully tuned, rejection only by HR mirror				
moharmonic.0003	same	same	800	1.0

⁺Crude estimate at beamline is $2-3 \times 10^{4}$ harmonic photons/sec.

Crude estimate at beamline is 10³ harmonic photons/sec.

BASE NOISE LEVEL: Experiment Log

Record at 10 keV for 3 minutes. Record with beam off for 3 minutes. Record data with knife edge 1/2 way through beam, Horizontal and Vertical, for 3 minutes.

- $_{\odot}$ $\,$ Harmonic rejection mirror set to 5 mRad. on the HR mirror.
- Return to standard optimized settings:
 - \circ Monochromator detuned by 10% on pre-slit detector.
 - Re-centered IO slits.
 - Slit size $H \times R = 6 \text{ mm} \times 1.1 \text{ mm}$ (est.)

Dummy scan for 3 minutes at 1 sec/pt (180 points). Estimated run time for scan is 3 min. 18 seconds. Measure offsets. Gains are IO 20 nA/V; IT 10 nA/V.

filename	condition	p-p on µ	topoff event
beam_noise.0001	10 keV	2 × 10 ⁻⁴	0.5%
beam_noise.0002	beam off		
beam_noise.0003	1/2 blocked Vert.		

We took the harmonic rejection mirror back to zero angle to double check the angle calibration. The mirror not have been correctly aligned for the previous measurements, and we may want to repeat HARMONIC CONTENT evaluation.

BREAK FOR LUNCH 12:43.

Construction noise seemed to settle down around 3pm. At least most of the grinding, drilling, and hammering has stopped.

5/2/06

DATA QUALITY: Experiment log

Transmission EXAFS of solutions with 0.1 edge step in ca. 2 absorption lengths of water. Cover a range of energies (Cl, Zn, Cd).

Solutions and transmission cells prepared by Matt Newville using dilution calculations by Bruce Ravel.

zinc nitrate

445 mg Zn(NO3)2•6H2O (Alfa #22403)

was dissolved into \approx 40 ml H₂O (Fischer W2-4 DIVF water) and stirred for 5 minutes.

The solution was then brought to 50 ml.

cadmium nitrate

626 mg Cd(NO₃)2•6H₂O (Alfa #21853)

was dissolved in ≈ 25 ml H₂O (Fischer W2-4 DIVF water) and stirred for 5 minutes.

The solution was then brought to 30 ml.

Beamline 10% detuned on pre-slit; HR mirror at 5 mRad; N2 in IO (15 cm) and IT (30 cm) at 600 VDC.

filename		slit size	edge step height	
znsolution.0001	0.2 sec/pt	1.1 mm x 6 mm	0.12	
znsolution.0002	1 sec/pt	1.1 mm x 10 mm		ca. 10^-3 noise
znsolution.0003	repeat	repeat		

Beamline Ar in IO (15 cm) and IT (30 cm) at 600 VDC; HR mirror to 2.3 mRad; close slits to 800 μ m x 10,000 μ m; beam height changed with large energy change (from 10 keV to 20 keV); The flux seems too low, so SH takes the HR mirror back to zero angle and adjusts height to center in beam. It was off by 800 μ m, which is the same as the entrance slit height, so this error had a huge effect on the flux. Nominal Cd edge position is 26,713 eV.

IO	IT
50 nA/V	50 nA/V

EXAFS scan parameters saved as JPEG.

filename		slit size	edge step height	
cdsolution.0002	1 sec/pt	0.8 mm x 10 mm	0.14	
cdsolution.0003	repeat	repeat		

Cd and Zn have comparable flux, noise, and reproducibiliby.

(6) FLUX at 10 keV: Measure on all beamlines with a common detector/amplifier combination.

ADC 10 cm detector, 1000 VDC, N2 stp, slit size is 1 x 10 mm, 4.1% absorption

detuning		HR mirror	gain	current	flux†
10%	1000 VDC	5 mRad	10 nA/V	2.309 V (offset corrected)	1.1e10
same	500 VDC	same	same	2.296 V	

tcalculated using PNC web programs

DETECTOR LINEARITY: Experiment Log

Move a knife edge or aperture across the incident beam and monitor the IO/IT ratio. Apparently there are several different types of linearity tests one could perform. We debate the merits and

applicability, and decide to perform a slit scan: scan a narrow slit across the beam horizontally, to see how uniform the detector is from side to side.

filename	beam size		IO	IT	comments
	н	V			
HSlitScan.0003	1 mm	1 mm	2 nA/V	2 nA/V	check uniformity of the ionization
					chambers from side to side
attenuatorscan.0001	1 mm	10 mm	20 nA/V	20 nA/V	Also used IRef at 10 nA/V.
					Dummy scan, with manually
					inserted layers of 12.5 μ m Mo
					foil

Monochromator detuned 10% on pre-slit; HR mirror at 5 mRad; N2 in IO[15 cm] and IT[30 cm]

5/2/06

BEAMLINE OPERATIONS

Practical limits on energy range for EXAFS (highest and lowest measured spectra) Chlorine, but requires major modifications to "standard" configuration to reduce attenuation. Ease of changing energy Large energy changes, such as from 10 keV (Zn) to 25 keV (Cd) required some manual adjustment of the optics, including the HR mirror zero, HR mirror tilt (normal, since cutoff energy is different), detuning, slit size (to match HR mirror acceptance), gains, detector gases. Availability of detectors <comment> Availability of special sample environments (high/low temp., vacuum, pressure, etc.) <comment> Ease of integrating APS Pool Detectors and Equipment <comment> Data collection software <comment> On-line data processing and analysis <comment> Sources of systematic errors (random electronic noise, known monochromator glitches, etc.) <comment> SOFTWARE CAPABILITIES (need to make a table for this) maximum number of regions for energy scans k-space scanning k-weighted integration time automatic offset correction macro capabilities plotting capabilities on-line analysis capabilities example of data file header (what information is automatically recorded)

9.1 % absorption at Cd, 15 cm Ar. estimated flux is 8x10^9 above the edge.